

TRINITY CONTAINERS 119 W.G. ASME VERTICAL TANK

General Specifications

Conforms to the latest edition and addenda of the ASME code for Pressure Vessels, Section VIII Division I. Complies with NFPA 58.

Rated at 250 psig MAWP from -20° F. to 125° F. All tanks may be evacuated for a full (14.7 psi) vacuum.

Vessels are delivered with pre-purge vacuum that is in compliance with the National Propane Gas Association #133-89(a) Alternative Purge.

Vessel finish: Coated with TGIC powder.

Patent pending.

